

GOVERNMENT OF ANDHRA PRADESH
FIRE PREVENTION WING, MUNICIPAL CORPORATION, TIRUPATI.
RENEWAL FIRE NO OBJECTION CERTIFICATE

From:
The Commissioner,
Municipal Corporation,
Tirupati

To:
The Director,
Central Board of Secondary Education,
New Delhi.

R.C.No.119/FPW/R-NOC/MCT/2019, Dt.12.07.2021.

Sir,

Sub :	Municipal Corporation – Fire Prevention Wing – Existing Non Multi Storeyed building of Bharatheeya Vidya Bhavan's Sri Venkateswara Vidyalaya, Alipiri, Tirupati Town & urban Mandal of Chittoor District – Renewal Fire No Objection Certificate for Occupancy – Issued.
Ref :	1. Memo. No: 12323/M1/2009 of MA & UD (M) Dated: 06.04.2010 and Letter Rc.No: 5041/B2/97 of The Director General, A.P. State Disaster Response & Fire Services Department, A.P., Hyderabad. Dated: 12-03-2010.
	2. This office occupancy Fire No Objection Certificate Vide R.C.No:119/ FPW/ TMC /2014, dt. 30.06.2014 of RFO , FPW MC,Tirupathi .
	3. Application No: Nil, Dated:15:06:2021 of the Management of Bharatiya Vidya Bhavan's sri Venkateswara Vidyalaya, Alipiri, Tirupati.
	4. Inspection Report R.c.No:119/FPW/R-NOC/MCT/2014, Dt:25.06.2021.

@@@

Under the powers delegated vide references 1st cited, the officers from Fire Prevention Wing, Municipal Corporation, Tirupati have inspected the existing building premises of Bharatheeya Vidya Bhavan's Sri Venkateswara Vidyalaya, Alipiri, Tirupati Town & urban Mandal of Chittoor District on 22.06.2021 and submitted the following report.

2. The existing Non Multi Storeyed School building consisting of Cellar+Ground + 02 upper Floors with a height of 12.00 Mtrs for Educational Occupancy (B). The Management has obtained occupancy Fire No Objection Certificate 2nd cited and now they have applied for Renewal Fire No Objection Certificate vide 3rd cited .

3. Particulars of the existing building:-

a.	Address of the building	Bharatiya Vidya Bhavan's Sri Venkateswara Vidyalaya, Alipiri, Tirupati Town & urban Mandal of Chittoor District
b.	Plot area/Height of the Building	40483.27 Sq.Mtrs / 12.00 Mtrs
c.	No of blocks / floors	02 / Block :A - Cellar +Ground + Two Upper Floors Block :B- Ground Floor (Auditorium Building)
d.	Type of occupancy	Educational Occupancy (B).

4. Fee Particulars:

Sl.No	Fee Details	Challan No. & Date	Amount	Remarks
1.	Renewal of Fire NOC	Deposit cheque No:-30002096220 dated: 08.06.2021 and at Municipal Treasury, Tirupati	Rs: 243800/-	----
	Total		Rs: 243800/-	--

A. N. V. Sree
PRINCIPAL
BHARATIYA VIDYA BHAVAN'S
SRI VENKATESWARA VIDYALAYA
TIRUPATI

HON. DIRECTOR & TREASURER
BHARATIYA VIDYA BHAVAN'S
SRI VENKATESWARA VIDYALAYA
TIRUPATI

Continued in page..2

::2::

5.a. Floor Wise Occupancy details:(BLOCK-1 Education Building)

Sl.No.	No. of Floor	Built up Area (in Sq. Mtrs.)	Type of Occupancy	Occupant Load as given the management.
1.	Cellar	750.25	Store Rooms	-----
2.	Ground	4733.36	Educational	1180
3.	First	2343.15	Educational	350
4.	Second	1547.00	Educational	350
Total		9373.76		1880

b. Means of Escape (Staircase):

Sl.No.	Details of Staircases	Required		Provided		Location of the staircases
		Nos.	Width in Mtrs	Nos.	Width in Mtrs	
1.	Internal	One	01.50	03 Nos.	4.50	South side -02 Nos West Side- 01 No.
2.	External	One	01.25	02 Nos.	3.00	East side- 02 No.
Total		2 Nos.	02.75	05 Nos.	07.50	

c. Details of Occupant Load per unit Exit width in Upper floor.

Maximum No. of occupants in the upper floor	Required Means of Escape in Meters	Provided in Meters	Deficit
400	$350/50=07.50$	07.50	Nil

6.BLOCK-2 Auditorium Building: -

S.No	No. Floor	Built up Area (in Sq. Mtrs.)	Type of Occupancy	Occupant Load
1.	Ground	1825	Auditorium	350
Total		1825		350

7. FIRE PROTECTION AND FIRE RECAUTIONARY MEASURES(Block A&B) . The builder has provided the following Fire Fighting Systems as per Fire No Objection Certificate for Occupancy NOC is as follows.

S.No	Fire Fighting Installations	Required	Provided
1.	Fire Extinguishers (Entire Building)	120 Nos.	120 Nos.
2.	Hose Reel System (For G+2 Building part only)	11 Nos.	11 Nos.
3.	Down comer system (For Auditorium building only)	03 Nos.	03 Nos.
4.	Sprinklers system (For cellar only)	63 Nos.	63 Nos.
5.	Terrace Tank capacity in Ltrs	10,000	15,000
6.	Fire Pump of 900 LPM	01	01

A. Nani Sree
PRINCIPAL
BHARATIYA VIDYA BHAVAN'S
SRI VENKATESWARA VIDYALAYA
Campus, All...

HON. DIRECTOR & TREASURER
BHARATIYA VIDYA BHAVAN'S
SRI VENKATESWARA VIDYALAYA
TIRUPATI

Continued in page..3

::3::

8. In View of the above, the Renewal of Fire No Objection Certificate is hereby issued to Bharatheeya Vidya Bhavan's Sri Venkateswara Vidyalaya, Alipiri, Tirupati Town & urbanMandal of Chittoor District. subject to the following Conditions:

- The Renewal NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use/Occupancy or Building Regularization. The Owner/ Occupier shall comply the Building Rules/Govt. Orders as applicable. This is without any prejudice to the action taken by MCT against Unauthorized Construction, if any.
- Evacuation plan showing exit routes and recommended action plan shall be displayed at conspicuous locations and shall be exhibited at all times, all escape /exit routes shall not be blocked or encroached.
- Fresh NOC would be required for any change in occupancy as per NBC and building Bye laws.
- The management has to maintain Fire Safety Measures at all times in good working Condition as seen during the time of inspection.
- Any Loss of life or property due to Non-functioning of Fire Safety Measures and other installations shall be the responsibility of the management/owner.
- All the Occupants must know the correct method of operation of the Fire Fighting System installed.
- All occupants/security personnel shall be trained to operate the Fire safety Equipment during the Emergency.
- The Fire Drills shall be conducted once in every Six months duly inviting local fire Station officer.

9. The issuance of Renewal of Fire No Objection Certificate is valid up to 29-06-2026 as per G.O.Ms No:169, Date:19.12.2019 of Home(Prisons& Fire)Department . The Management has to submit Undertaking letter every year on working condition of the Fire Safety Equipment installed in the building and also for the purpose of inspection of officers from Fire Prevention Wing, Municipal Corporation, Tirupati. Also, the Management has to submit advance Taxes paid Receipts every year while submitting undertaking letter. It is the responsibility of the Management/Occupier to apply for renewal of Fire NOC before two months of expiry date.

--sd--

(GIRISHA.PS. IAS,)

Commissioner,

Municipal Corporation, Tirupathi.

//Attested//

(R.GNANA SUNDARAM)

Regional Fire Officer,

Municipal Corporation,

Tirupati.

A. Vani Sree
PRINCIPAL
BHARATIYA VIDYA BHAVAN'S
SRI VENKATESWARA VIDYALAYA

HON. DIRECTOR & TREASURER
BHARATIYA VIDYA BHAVAN'S
SRI VENKATESWARA VIDYALAYA

Copy to the Management of Bharatiya Vidya Bhavan's Sri Venkateswara Vidyalaya,
Alipiri, Tirupati Town & urban Mandal of Chittoor District of A.P.